



Contribution ID: 183

Type: **Oral Presentation**

Investigations on hearth refractory and skull

Wednesday 8 October 2025 17:30 (20 minutes)

The Gwangyang Blast Furnace No. 3 experienced an early relining approximately 12 years after its initial blow-in due to premature wear of copper staves leading to shell damage and damage to the hearth cooling system caused by hot metal leakage at the No.1 taphole. To expand the internal volume from 4600 m³ to 5500 m³, a complete dismantling of the furnace body was undertaken. During this period, core boring was conducted in areas where the hearth cooling system was damaged to sample the hearth refractory and skull. These samples were analyzed for their composition, conductivity, and other properties based on their location. The study results provide insights into the material degradation mechanisms and inform strategies for enhancing the durability and performance of blast furnace components.

Primary author: KIM, Jungil (POSCO)

Co-authors: Mr PARK, Jeongjun (POSCO); Dr SHIN, Minsoo (POSCO); Dr CHOI, Sangwoo (POSCO); Dr LEE, Seungmoon (POSCO)

Presenter: KIM, Jungil (POSCO)

Session Classification: Refractory & Equipment Maintenance

Track Classification: Ironmaking - Blast furnace ironmaking